



P.O. Box 428 • 110 Kings Road • Kings Mountain, N.C. 28086-0428 • Tele: 704-739-7415 • Fax: 704-739-7416

E-mail: bfec@buckeyef.com • Internet: <http://www.buckeyef.com/fire>

DECLARATION OF CONFORMITY

Equipment Manufacturer: Buckeye Fire Equipment Company
110 Kings Road
Kings Mountain, NC 28086 USA

Product Designation: Kitchen Mister Restaurant Fire Suppression System

Equipment Type: Restaurant Fire Suppression System

Standards: UL-300, UL-1254, NFPA-17, NFPA-17A



Product Description: The Kitchen Mister Restaurant Fire Suppression System is a pre-engineered wet chemical restaurant fire suppression system as defined by the NFPA-17A Standard for Wet Chemical Extinguishing Systems. It is a stored pressure type system that discharges a pre-determined amount of fire extinguishing agent through a fixed piping system and fixed nozzles. System conformance applies to all equipment described in the UL Listed Design, Installation, and Maintenance Manual, P/N BFR-TM.

Associated Equipment: System components include but are not limited to Model SRM Systems Releasing Module, Models N-1L/1H/2L/2H/2W Discharge Nozzles, Model MB-1 and MB-2 Mounting Brackets, and Model RPS-M Remote Pull Station.

European Community Council Directive 97/23/EC: Assemblies bearing the CE mark in accordance with Directive 97/23/EC include the following equipment:

Model BFR-5 - 1.9 (7.2 L) gallon cylinder assembly
Model BFR-15 - 5.7 (21.6 L) gallon cylinder assembly
Model BFR-AC-S/L Nitrogen Activation Cartridge

Model BFR-10 - 3.8 (14.4 L) gallon cylinder assembly
Model BFR-20 - 7.6 (28.8) gallon cylinder assembly

European Community Council Machinery Directive 89/392/EEC and 91/368/EEC: Assemblies bearing the CE mark in accordance with Directive 89/392/EEC (as amended by Directive 91/368/EEC) include the following equipment:

Model BFR-SRM Systems Releasing Module
Model BFR-SRM-D Dual Systems Releasing Module

European Community EMC Low Voltage Directives 73/23/EEC and 93/68/EEC: Assemblies bearing the CE mark in accordance with Directives 89/392/EEC/73/23/EEC and 93/68/EEC include the following equipment:

Model BFR-SRM Systems Releasing Module
Model BFR-SRM-D Dual Systems Releasing Module
Model BFR-MS-DPDT Miniature Electrical Switch

Declaration

We hereby certify that the equipment as specified herein conforms to all applicable requirements of the Directive and underlying standard.

William Vegso

Manager of Research and Development

Date: October 11, 2010

Buckeye Fire Equipment Company
ISO 9001 Registered