


FDMR 180

Fire damper

Technical Documentation Installation, Commissioning, Operation, Maintenance and Service Manual







These technical specifications state a row of manufactured sizes and models of fire dampers FDMR 180. It is valid for production, designing, ordering, delivery, maintenance and operation.

CONTENT

I. GENERAL	3
Description	3
II. DESIGN	4
Design with manual control	4
Design with spring return actuator	6
Design with the communication and supply device	12
Communication and control device BKS 24-1B and BKS 24-9A	17
III. DIMENSIONS	19
Technical parameters	24
IV. INSTALLATION	25
Placement and installation	25
Statement of installations	26
In solid wall construction	27
In solid ceiling construction	28
V. SUSPENSION SYSTEMS	29
Example of duct connection	31
VI. TECHNICAL DATA	32
Pressure loss	32
Noise data	33
VII. MATERIAL, FINISHING	34
VIII. TRANSPORTATION, STORAGE AND WARRANTY	35
Logistic terms	35
Warranty	35
IX. ASSEMBLY, ATTENDANCE AND MAINTENANCE	36
Commissioning and revisions	38
X. ORDERING INFORMATIONS	40
Ordering key	40
Data label	41



I. GENERAL

Description

Fire dampers are shutters in ducts of air-conditioning devices that prevent the spread of fire and combustion products from one fire segment to the other one by means of closing the duct in the points of fire separating constructions.

Damper blade automatically closes air duct using a closing spring or a spring return actuator. The closing spring is actuated by pressing a button on the manual control or by melting a thermal fuse.

The return spring of the actuator is actuated when a thermoelectric activation device BAT is activated, when a test button on BAT is pressed or when power supply of the actuator is interrupted.

After closing the blade, the damper is sealed with silicon against smoke penetration. On request by customer, the damper can be supplied silicon-free. In the closed position, the damper is also sealed with material which increases its volume due to increasing temperature and air proofs the air duct.



FDMR 180 with spring return actuator



FDMR 180 with manual control

Damper characteristics

- CE certified acc. to EN 15650
- Tested in accordance with EN 1366-2
- Classified acc. to EN 13501-3+A1
- External Casing leakage class min. C acc. to EN 1751
- Internal leakage min. class 3 acc. to EN 1751
- Cycling test in class C₁₀₀₀₀ acc. to EN 15650
- Corrosion resistant acc. to EN 15650
- Certificate of constancy of performance No. 1391-CPR-2023/0085
- Declaration of Perfomance No. PM/FDMR180/01/23/1
- Hygienic assessment of fire dampers Report No. 1.6/pos/19/19b

Working conditions

- Exact damper function is provided under the following conditions:
 - maximum air velocity 12 m/s
 - maximum pressure difference 1200 Pa
 - the air circulation in the whole damper section must be secured steady over the entire surface.
- Dampers can be installed in arbitrary position
- Dampers are suitable for systems without abrasive, chemical and adhesive particles.
- Dampers are designed for macroclimatic areas with mild climate according to EN IEC 60 721-3-3 ed.2., class 3K22. (Environment 3K22 is typically protected place with regulated temperature)
- Temperature in the place of installation is permitted to range from -30°C to +50°C.





II. DESIGN

Design with manual control

Design .01

- Design with manual control with a thermal fuse which actuates the shutting device, after the nominal activation temperature 72°C has been reached.
- Automatic initiation of the manual control is not activated if the temperature does not exceed 70°C.





Design .01


ATTENTION:

- Manual controls are produced in five sizes M1 to M5, difference is only in size of a closing spring, which closes the fire damper.
- For the size of fire dampers is always assigned the size of the manual control → see page 24
- It is not recommended to use different size of the manual control than given by the manufacturer, otherwise there is a risk of damaging the fire damper.

Design .11

 Design .01 with manual control can be complemented with a limit switch signaling of the damper blade position "CLOSED".


- Cable is connected directly to limit switch.
- Limit switch detail → see page 5



Design .11


Design .80


- Design .01 with manual control can be complemented with two limit switches signaling of the damper blade position "CLOSED" and "OPEN".
- Cables are connected directly to limit switches.
- Limit switch detail → see page 5



Design .80







Nominal voltage and maximal current	AC 230V / 5A
Class of protection	IP 67
Working temperature	-25°C +120°C

This limit switch is possible to connect in two following ways

- CUT-OFF if the arm is moving ... connect wire 1+2
- SWITCH-ON if the arm is moving ... connect wire 1+4



Design with spring return actuator

Design .40 and .50

- The fire dampers are equipped with Belimo spring return actuators with thermoelectric activation device BAT. The spring return actuator types are BFL, BFN or BF depending on the damper size. (Further mentioned as "actuator").
- After being connected to power supply 230V or AC/DC 24V, the actuator rotates the damper blade to the operating position "OPEN" and at the same time prestretches its return spring.
- When the actuator is power supplied, the damper blade is in the position "OPEN" and the return spring is prestretched.
- Time needed for full opening of the damper blade from the position "CLOSED" to the position "OPEN" is maximum 120 sec. If the actuator power supply is interrupted (due to loss of supply voltage, or pressing a test button on the thermoelectric activation device BAT), the actuator rotates the damper blade to the breakdown position "CLOSED".
- The time of closing the damper blade from the position "OPEN" to the position "CLOSED" takes maximum 20 sec.


- In case that the power supply is restored again (the blade can be in any position), the actuator starts to rotate the damper blade back to the position "OPEN".
- A thermoelectric activation device BAT, which contains two thermal fuses Tf1 and Tf2, is an integral part of the actuator.
- These fuses are activated when temperature +72°C has been reached (the fuse Tf1 due to temperature outside the duct and the fuse Tf2 due to temperature inside the duct). The thermoelectric activation device can also be equipped with a Tf2 thermal fuse type ZBAT 95/120/140 (must be specified in the order). In this case, the activation temperature inside the duct is +95°C, +120°C or +140°C (depending on the type).
- After the thermal fuse Tf1 or Tf2 has been activated, the power supply is permanently and irreversibly interrupted and the actuator, by means of the pre-stretched spring, rotates the damper blade into the breakdown position "CLOSED".
- Signalisation of damper blade position "OPEN" and "CLOSE" is provided by two microswitches.




Design .40 and .50



Actuator BELIMO BFL 230-T



Actuator BELIMO BFL 24-T(-ST)







Ad	tuator BELIMO BFL 230-T(-ST), BFL 24-T(-ST	.)	
Actuator BELIMO - 4 Nm/ 3 Nm Spring	BFL 230-T(-ST)	BFL 24-T(-ST)	
Power voltage	AC 230 V	AC/DC 24 V	
rowei voitage	50/60Hz	50/60Hz	
Power consumption - in operation	3,5 W	2,5 W	
- in rest position	1,1 W	0,8 W	
Dimensioning	6,5 VA (Imax 4 A @ 5 ms)	4 VA (Imax 8,3 A @ 5 ms)	
Protection class	П	III	
Degree of protection	IP 54		
Running time - motor	< 60 s		
- spring return	~ 20 s		
Ambient temperature			
- normal duty	-30°C .	+55°C	
- safety duty	The safe position will be	attained up to max. +75°C	
 non-operating temperature 	-40°C +55°C		
Connection - supply/control	cable 1 m, 2 x 0,75 mm² (BFL 2xx-T-ST) with 3-pin plug-in connectors		
- auxiliary switch		T-ST) with 6-pin plug-in connectors	
Response temperature thermal fuse	duct outside ter	mperature +72°C	
nesponse temperature thermal ruse	duct inside tem	nperature +72°C	



Actuator BELIMO BFN 230-T



Actuator BELIMO BFN 24-T(-ST)







Act	tuator BELIMO BFN 230-T(-ST), BFN 24-T(-S	ST)
Actuator BELIMO - 9 Nm/ 7 Nm Spring	BFN 230-T(-ST)	BFN 24-T(-ST)
Power voltage	AC 230 V 50/60Hz	AC/DC 24 V 50/60Hz
Power consumption - in operation - in rest position	5 W 2,1 W	4 W 1,4 W
Dimensioning	10 VA (Imax 4 A @ 5 ms)	6 VA (Imax 8,3 A @ 5 ms
Protection class	II	III
Degree of protection	IP 54	
Running time - motor - spring return	< 60 s ~ 20 s	
Ambient temperature - normal duty - safety duty - non-operating temperature	The safe position will be	+55°C attained up to max. +75°C +55°C
Connection - supply/control - auxiliary switch	cable 1 m, 2 x 0,75 mm 2 (BFN 2xx-T-ST) with 3-pin plug-in connectors cable 1 m, 6 x 0,75 mm 2 (BFN 2xx-T-ST) with 6-pin plug-in connectors	
Response temperature thermal fuse	duct outside temperature +72°C duct inside temperature +72°C	



Actuator BELIMO BF 230-TN



Actuator BELIMO BF 24-TN (-ST)






Act	uator BELIMO BF 230-TN(-ST), BF 24-TN(-ST	Γ)	
Actuator BELIMO - 18 Nm/ 12 Nm Spring	BF 230-TN(-ST)	BF 24-TN(-ST)	
Power voltage	AC 230 V	AC/DC 24 V	
rowei voitage	50/60Hz	50/60Hz	
Power consumption - in operation	8,5 W	7 W	
- in rest position	3 W	2 W	
Dimensioning	11 VA (Imax 8,3 A @ 5 ms)	10 VA (Imax 8,3 A @ 5 ms)	
Protection class	II	III	
Degree of protection	IP 54		
Running time - motor	120 s		
- spring return	~ 16 s		
Ambient temperature			
- normal duty	-30°C .	+50°C	
- safety duty	The safe position will be attained up to max. +75°C		
 non-operating temperature 	-40°C +50°C		
Connection - supply/control	cable 1 m, 2 x 0,75 mm ² (BF 2xx-TN-ST) with 3-pin plug-in connectors		
- auxiliary switch	cable 1 m, 6 x 0,75 mm² (BF 2xx-TI	N-ST) with 6-pin plug-in connectors	
Response temperature thermal fuse	duct outside ter	nperature +72°C	
nesponse temperature thermal ruse	duct inside tem	nperature +72°C	



Thermoelectric activation device BAT

- If the thermal fuse Tf1 is interrupted (due to temperature outside the duct), it is necessary to replace the spring return actuator. Thermoelectric activation device BAT is integral part of the actuator.
- If the thermal fuse Tf2 is interrupted (due to temperature inside the duct) , only the spare part ZBAT 72 (95/120/140) needs to be replaced (acc.to the activation temperature).
- When one of the thermal fuses responds, the supply voltage is interrupted permanently and irreversibly.
- The function (interruption of the supply voltage) can be checked by pressing the test button.
- Installation is carried out with the pre-assembled, selftapping screws.




Thermoelectric activation device BAT 72 (95/120/140)		
Power voltage	AC/DC 24 V 50/60Hz	
Rated current	1 A	
AC/DC throughput resistance	<1Ω	
Protection class	III	
Degree of protection	IP 54	
Probe length	65 mm	
Ambient temperature Storage temperature Ambient humidity	-30°C +50°C -40°C +50°C Max. 95% RH, non-condensing	
Connection supply	Cable 1 m, 2 x 0.5 mm², Betaflam cable heatresistant up to 145°C	
Response temperature thermal fuse	Duct inside temperature +72 (95/120/140)°C Duct outside temperature +72 (95/120/140)°C	




Design .41 and .51

- Design .41 or .51 with actuator and smoke detector ORS 142 K. The voltage can be AC 230 V or 24 V DC. Design .41 with voltage AC 230 V is equipped with communication and supply device BKN 230-24-MOD and with actuator BF 24-TN (BFL 24-T, BFN 24-T).
- The smoke detector is activated when smoke spreads in air duct system. Deactivation of the smoke detector alarm
- status is provided by interruption of supply voltage for min. 2s.
- Signalisation of damper blade position "OPEN" and "CLOSE" is provided by two microswitches.
- The smoke detector is not part of the damper in diameter DN 200 mm. The smoke detector is supplied separately.

Design .41 with actuator BF 24-TN (BFL, BFN 24-T), with smoke detector ORS 142 K and with supply device BKN 230-24-MOD (voltage AC 230 V)



Design .51 with actuator BF 24-TN (BFL, BFN 24-T), with smoke detector ORS 142 K (voltage 24 V DC)



Communication and supply device BKN 230-24-MOD		
Nominal voltage	AC 230 V 50/60Hz	
Power consumption	3 W (operating position)	
Dimensioning	14 VA (including actuator)	
Protection Class	II	
Degree of protection	IP 40	
Ambient temperature Non-operating temperature	-20°C +50°C -40°C +80°C	
Connection - net - motor - terminal board	cable 0,9 m with EURO plug type 26 6-pole connector, 3-pole connector screw terminals for cable 2x1,5 mm ²	




Design with the communication and supply device

Design .60

- Design with the communication and supply device BKN 230-24 and actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST). It simplifies electrical wiring and interconnection of fire dampers. It facilitates on site check and enables central control and checks of fire dampers by means of a simple 2-conductor wiring.
- BKN 230-24 functions as a decentralized network device for supplying the actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) further it transmits the signal informing about the damper blade position OPERATION and FAILURE through 2-conductor wiring to the central.
- Control command SWITCHED ON SWITCHED OFF from the central through BKN 230-24 goes through the same wiring to the actuator.
- To simplify the connection, the actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) is equipped with connecting plugs that are inserted directly to BKN 230-24. BKN 230-24 is supplied with a conductor and an EURO plug to be connected to the 230V mains. 2-conductor wiring is connected to BKN 230-24 by means of terminals 6 and 7. If the actuator is supposed to be controlled without any signal from the central, it can be switched on by means of a bridge between the terminals 3 and 4.
- A green LED on BKN 230-24 is on when voltage is present in the drive (AC 24V).
- If the test button on BAT is pressed or if the power supply (e.g. by a signal from ELECTRICAL FIRE SIGNALISATION) is disconnected, the damper blade position will be "FAILURE".

Communication and supply device BKN 230-24, with actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST)



Communication and supply device BKN 230-24		
Nominal voltage	AC 230 V 50/60Hz	
Power consumption	3,5 W (operating position)	
Dimensioning	11 VA (including actuator)	
Protection Class	II	
Degree of protection	IP 40	
Ambient temperature Non-operating temperature	-20°C +50°C -40°C +80°C	
Connection - net - motor - terminal board	cable 0,9 m with EURO plug type 26 6-pole connector, 3-pole connector screw terminals for cable 2x1,5 mm ²	




Design .61, 61S

- Design with the communication and supply device BKN 230-24-C-MP, and actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST). It simplifies electrical wiring and interconnection of fire dampers. Enables central control and checks of fire dampers by means of a simple 2-conductor wiring and it also allows connection to the system via MP-BUS communication. Design 61. can be extended with an optical smoke detector ORS 142 K (design .61S).
- BKN 230-24-C-MP functions as a decentralized network device for supplying the actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) further it transmits the signal informing about the damper blade position OPERATION and FAILURE through 2-conductor wiring to the central.
- Control command SWITCHED ON SWITCHED OFF from the central through BKN 230-24-C-MP goes through the same wiring to the actuator.
- To simplify the connection, the actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) is equipped with connecting plugs that

- are inserted directly to BKN 230-24-C-MP. BKN 230-24-C-MP is supplied with a conductor and an EURO plug to be connected to the 230V mains. 2- conductor wiring is connected to BKN 230-24-C-MP by means of terminals 6 and 7. If the actuator is supposed to be controlled without any signal from the central, it can be switched on by means of a bridge between the terminals 3 and 4.
- A green LED on BKN 230-24-C-MP is on when voltage is present in the drive (AC 24V).
- If the test button on BAT is pressed or if the power supply (e.g. by a signal from ELECTRICAL FIRE SIGNALISATION) is disconnected, the damper blade position will be "FAILURE".
- For design 61S the smoke detector is activated when smoke spreads in air duct system. Deactivation of the smoke detector alarm status is provided by interruption of supply voltage for min. 2s.
- The smoke detector is not part of the damper in diameter DN 200 mm. The smoke detector is supplied separately.

Design with communication and supply device BKN 230-24-C-MP, with actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) and smoke detector ORS 142 K



Communication and supply device BKN 230-24-C-MP Nominal voltage AC 230 V 50/60Hz Power consumption 3,5 W (operating position) Dimensioning 10 VA (including actuator) **Protection Class** Ш Degree of protection IP 40 -20°C ... +50°C Ambient temperature -40°C ... +80°C Non-operating temperature cable 0,9 m with EURO plug type 26 Connection - net - motor 6-pole connector, 3-pole connector - terminal board screw terminals for cable 2x1,5 mm²




Design .63, 63S

- Design with the communication and supply device BKN 230-24-MOD and actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) for communication with control systems using the Modbus RTU or BACnet MS / TP. Design 63. can be extended with an optical smoke detector ORS 142 K (design .63S).
- The wiring of the line is to be carried out in accordance with applicable RS485 regulations.
- Parameterization of the communication is done using DIL switches.
- BKN 230-24-MOD can be installed separately, without a connection to a master control system, in which case the

- connection bridge between the terminals 1 and 4 must be installed.
- If the test button on BAT is pressed or if the power supply (e.g. by a signal from ELECTRICAL FIRE SIGNALISATION) is disconnected, the damper blade position will be "FAILURE".
- For design 63S the smoke detector is activated when smoke spreads in air duct system. Deactivation of the smoke detector alarm status is provided by interruption of supply voltage for min. 2s.
- The smoke detector is not part of the damper in diameter DN 200 mm. The smoke detector is supplied separately.

Design with communication and supply device BKN 230-24-MOD, with actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) and smoke detector ORS 142 K




Communication and supply device BKN 230-24-MOD		
Nominal voltage	AC 230 V 50/60Hz	
Power consumption	3 W (operating position)	
Dimensioning	14 VA (including actuator)	
Protection Class	II	
Degree of protection	IP 40	
Ambient temperature Non-operating temperature	-20°C +50°C -40°C +80°C	
Connection - net - motor - terminal board	cable 0,9 m with EURO plug type 26 6-pole connector, 3-pole connector screw terminals for cable 2x1,5 mm ²	



Design .62

- Design with the communication and supply device BKN 230-24MP and actuator BF 24TL-TN-ST for connection to MP-Bus.
- BKN 230-24MP supplies to the intelligent actuators of fire dampers BF 24TL-TN-ST decentrally needed power supply.
- In this way can be realize long MP-Bus communications (up to 800 m).
- Up to 8 Bus nodes can be parallel connected and controlled by Master device (DDC with interface).
- Device can be equipped with an external smoke detector.

Communication and supply device BKN 230-24MP



Communication and supply device BKN 230-24MP		
Nominal voltage	AC 230 V 50/60Hz	
Power consumption	8 W (including actuator)	
Dimensioning	10 VA (including actuator)	
Protection Class	II	
Degree of protection	IP 40	
Ambient temperature Non-operating temperature	-30°C +50°C -40°C +80°C	
Connection - net - motor (BFTop) - net MP - actuating mechanism (variable) - Top-Line PC-Tool (via ZIP-RS232)	cable 1 m with EURO plug 4-pole connector screw terminals 2-pole screw terminals 2-pole 3-pole connector	



Optical smoke detector ORS 142 K with the socket 143A

- The smoke detector ORS 142 K is used for early smoke detection in rooms or inside the ventilation system.
- The sensor operates on the light scatter principle. Inside the scanning chamber is a light source and a light sensor, in the normal state the light from the source does not fall on the senzor. Only when smoke enters the scanning chamber the light is scattered and falls on the senzor.
- The smoke detector can be connected directly to the actuator (design .41 and .51) which, in case of smoke detection, passes to the safety position, or to the BKN communication and supply device (design .61, .63).
- By early detection of smoke, it can be effectively prevented from spreading of smoke through the ventilation system. In addition to smoke detection, the sensor can distinguish and signal slight

- and heavy contamination, e.g. the presence of large amounts of
- The ORS 142 K smoke detector has an alarm memory, i.e. if the alarm is triggered, the safety relay opens and stays in this state even if the smoke disappears from the scanning chamber. The sensor remains in the alarm state until the power supply is briefly reset.
- On the pin 3, an external device can be connected via RS-Bus communication to report the status of the sensor.
- Pin 6 has no connection to the detector and is designed as a load-bearing structure in the base.


ORS 142 K













Relay conta	LED		
In operation		Green	Shines
Slight contamination	1	Green / Yellow	Flashes
Heavy contamination		Green / Yellow	Flashes
Fault		Yellow	Shines
Alarm	0 4 0 5	Red	Shines
Power Off		Off	_





20 33 59 5 6

Ø 80

3

- 1 ORS 142 K
- 2 Socket 143A
- 3 Side cable entries Ø 9mm
- 4 Rear cable entries Ø 9mm
- 5 Fixing hole Ø 4,5 mm
- 6 Fixing hole Ø 3,7 mm

Optical smoke detector ORS 142 K with the socket 143A Operating voltage 18 ... 28 V DC ≤ 200 mV Residual ripple Power Consumption Socket (without actuator) max. 22 mA Degree of protection **IP 42** -20°C ... +75°C Ambient temperature +70°C Aditional temperature senzor

Connection - net

- motor

- communication and supply device BKN

Cabel 1m, connected to terminals 1, 2 and 4 Actuator connected on the terminals 2 and 5 Cabel 1m, connected to terminals 1, 2, 4 and 5




Communication and control device BKS 24-1B and BKS 24-9A

Communication and control device BKS 24-1B

- BKS 24-1B communication and control device is used for control and checks of fire dampers with the BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) actuator in conjunction with the BKN 230-24 supply and communication device.
- BKS 24-1B receives information about the situation of the fire damper through BKN 230-24 supply and communication device and issues controlling commands.
- The device is intended for building in into the distribution board.
- Light diodes on the front side of the device signalise the operating situations of the damper and breakdowns of the whole system.
- Potentialless auxiliary contacts enable connection to the master control system (signaling of the damper position, failure reports, release of the ventilators etc.).
- While a flashing green LED pilot light signalises damper blade motion towards the given position, the same pilot light reports reaching the required position when shining constantly.

- If the damper blade, with respect to the given time, does not reach the required position, then a red LED pilot light starts to flash and at the same time, the failure contact is active.
- Once the damper blade reaches the given position, this contact is deactivated.
- The LED pilot light keeps flashing unless the failure is unblocked by means of the RESET button.
- Except for reporting failures, other three auxiliary contacts are available. Contacts showing operating and failure position of the damper are active when the damper is in the given position. Function check can be done by pressing and holding the button "RESET/TEST" for longer time. While holding the button, the damper blade rotates in the direction of the failure position. Fault function is indicated by the LED pilot light.
- BKS 24-1B can be connected by means of ZSO-11 11 pole connector for DIN 35 mm panel.





lig	light diodes		contacts	Description	
⊗ open	⊗ closed	alarm	state	Cause/Course	
⊗ closed	⊗ closed	Closed	6-43	Power supply AC 24Vnot available	
☆ open	- ☆ open	pen open	6-43	Check test cca 35sec, starting with switching AC 24 on or pressing «Reset/Test» button	
⊗closed	⊗ closed	· flashing	6-43	Current failure, possible cause: • short circuit or interruption of 2-conductor wiring or damper failure (at BKN) • Power supply AC 230V missing • defective thermoelectrical starting • smoke detector activated • exceeded operation time • damper blocked	
⊗closed	⊗ closed	- X -open	6-3	Failure saved in memory • Fault in system signalled, system check should be done	
⊗ closed	(Flashing	closed	6-4	Damper (drive) turning into the direction of breakdown position	
⊘ closed	- X → open	closed 🗷	6-4	Damper (drive) in breakdown position I	
Ö -flashing	⊗ closed	closed	6-7	Damper (drive) turning into the direction of operating position	
- X - open	⊗ closed	closed	6-47	Damper (drive) in operating position	

Communication and control device BKS 24-1B AC 24 V 50/60Hz Nominal voltage Power consumption 2,5 W (operating position) Dimensioning 5 VA **Protection Class** Ш **IP 30** Degree of protection 0°C ... +50°C Ambient temperature 11-pole connector ZSO-11, it is not part of BKS24-1B, Connection ZSO-11 is 11-pole screw terminal 11 x 1,5 mm²




Communication and control device BKS 24-9A

- BKS 24-9A communication and control device is used for group control and checks of 1 to 9 fire dampers with the actuator BF 24-TN-ST (BFL 24-T-ST, BFN 24-T-ST) in connection with the supply and communication device BKN 230-24.
- Signalisation of the damper position is individual; the damper can be controlled and tested only as a group.
- BKS 24-9A is intended for use in the distribution board and displays the operation situations and failure reports of the connected fire dampers.
- It is possible to signalise functions such as the damper position and failure reports or to transmit them further to the system by means of integrated auxiliary switches.
- BKS 24-9A receives signals from BKN 230-24 through the twoconductor wiring and issues control commands.

- Proper damper operation is indicated by two light LED diodes:
 - Control ON = position OPERATION
 - Control OFF = position FAILURE
- If the fire damper do not reach the given position in time tolerable for displacing, the appropriate light diode FAILURE starts to flash and K1 contact is opened (current failure).
- In case that the faulty damper finally reaches its given position, K1
 is closed and the failure report light shines (the failure is saved in
 memory).
- **K2** the auxiliary contact is used for signaling of the damper blade position to the master device.
- Function of this auxiliary contact can be programmed through the terminal 14.

Functio	on contact K1	Programming K	2 Auxiliary Contact	
situation	state	function interconnection		state
current failure	15 — 16	K2 contact is on if all dampers are open	14 11	
na failus	15 1 16	K2 contact is on if damper No. 1 is open	14 12	17 — 18
no failure	15 — 16	K2 contact is on if all dampers are closed	14 open	

- Function check can be done in the position OPERATION by means of pressing the TEST button.
- While the test button is pressed, damper blade is rotating into the position FAILURE.
- Fault function is indicated by a report "FAILURE".
- Assembly and connection BKS 24-9A can be made by DIN 35 mm panel. It is connected by two 9-pole plug-in connectors.



Notice: Relay contacts K1 and K2 are drawn without power

Communication and control device BKS 24-9ANominal voltageAC 24 V 50/60HzPower consumption3,5 WDimensioning5,5 VAProtection ClassIIIDegree of protectionIP 30Ambient temperature0°C ... +50°CConnectionterminal 2 x 1,5 mm²




III. DIMENSIONS

SPIRO design with manual control


DN 200 - DN 315

2 3 1 2 3 1 120 170 1 2 120 4 400 6

DN 350 - DN 500



DN 560 - DN 800




- 1 Damper casing
- 2 Manual control
- 3 Damper blade
- 4 Inspection opening cover
- 5 Sensor sticker
- 6 Hole for camera




FLANGE design with manual control

DN 200 - DN 315

2 3 1






	4	
Ød1 [mm]	Ød2 [mm]	n number of holes in the flange
235	10	8
260	10	8
285	10	8
315	10	8
335	10	12
350	10	12
390	10	12
445	12	12
495	12	12
545	12	16
605	12	16
650	12	16
680	12	16
760	14	20
860	14	20
	235 260 285 315 335 350 390 445 495 545 605 650 680 760	[mm] [mm] 235 10 260 10 285 10 315 10 335 10 390 10 445 12 495 12 545 12 605 12 650 12 680 12 760 14




- 2 Manual control
- 3 Damper blade
- 4 Inspection opening cover
- 5 Sensor sticker
- 6 Hole for camera

DN 355 - DN 500



DN 560 - DN 800






Design SPIRO with spring return actuator

DN 200 - DN 315The actuator cannot be rotated

1 5 2 5 2 3 1 50 300 50 50 1 5 5 6 6 6 6


DN 350 - DN 500

The actuator can be rotated 90°



DN 560 - DN 800

The actuator can be rotated 90°



- X=53 mm (BFL) * X=72 mm (BFN) * X=78 mm (BF) *
- 1 Damper casing
- 2 Spring return actuator
- 3 Damper blade
- 4 Inspection opening cover
- 5 Thermoelectric activation device BAT
- 6 Hole for camera


■ Assigment of actuators to individual sizes → see page 24





Design FLANGE with spring return actuator

DN 200 - DN 315

The actuator cannot be rotated







Ød	Ød1	Ød2	n
[mm]	[mm]	[mm]	number of holes in the flange
200	235	10	8
225	260	10	8
250	285	10	8
280	315	10	8
300	335	10	12
315	350	10	12
355	390	10	12
400	445	12	12
450	495	12	12
500	545	12	16
560	605	12	16
600	650	12	16
630	680	12	16
710	760	14	20
800	860	14	20

X=70 mm (BFL - DN 200 ÷ DN 315) * X=53 mm (BFL - DN 355 ÷ DN 400) * X=72 mm (BFN) *


1 Damper casing

X=78 mm (BF) *

- 2 Spring return actuator
- 3 Damper blade
- 4 Inspection opening cover
- 5 Thermoelectric activation device BAT
- 6 Hole for camera


DN 355 - DN 500

The actuator cannot be rotated



DN 560 - DN 800

The actuator cannot be rotated




■ Assigment of actuators to individual sizes → see page 24



Damper blade overlaps

■ Open damper blade overlaps the damper casing by the value "a" or "c". These values are specified in chapter Technical parameters → see page 24



Values "a" and "c" has to be respected when projecting following air-conditioning duct.

Fire damper with installation brackets

- Weight of the installation bracket is 0,06 kg.
- Number of installation brackets for individual sizes → see page 24





Technical parameters

Nominal size	ØD		We	eight	Number of	Effective		Manual control
ØD [mm]			Man. control [kg]	Spring return actuator [kg] ***	installation brackets *	area Sef [m²]	Spring return actuator	
200	-	-	5,4	5,6	3	0,0137	BFL	M1
225	-	-	6,1	6	3	0,0197	BFL	M1
250	-	-	6,8	7	3	0,0268	BFL	M2
280	-	12	7,8	8	3	0,0365	BFL	M2
300	-	23	8,5	8,7	3	0,0438	BFL	M2
315	-	30	9	9,2	3	0,0497	BFL	M2
350**	-	48	11,5	11,6	3	0,0648	BFL	M2
355	-	50	11,6	11,7	3	0,0671	BFL	M2
400	-	73	13,6	13,8	3	0,0897	BFL	M2
450	-	98	15,9	16,3	3	0,1185	BFN	M3
500	-	123	18,5	18,9	3	0,1512	BFN	M3
560	-	153	21,7	22,1	3	0,1957	BFN	M3
600	13	173	24,3	26,4	3	0,2284	BF	M4
630	28	188	24,7	26,8	3	0,2547	BF	M4
710	68	228	32	34,3	4	0,3305	BF	M4
800	113	273	38,2	40,4	4	0,4289	BF	M5

 $^{^{}st}$ Weight of an installation bracket is 0,06 kg.

^{**} Only spiro design SL or SK can be ordered.

^{***} For designs with BKN a weight of 0.5 kg must be added.



IV. INSTALLATION


Placement and installation

- The fire dampers are suitable for installation in arbitrary position in vertical and horizontal passages of fire separating constructions. The damper installation procedures must be done so that all load transfer from the fire separating constructions to the damper is absolutely excluded. Following air-conditioning duct must be suspended or supported so that all load transfer from the following duct to the fire damper is absolutely excluded. The gap between the installed damper and the fire separating construction must be perfectly filled with approved material.
- The damper must be installed so that the damper blade (in closed position) is situated in the fire separating construction - marked by the label BUILT-IN EDGE on the damper casing. If such solution is not possible, the duct

- between the fire separating construction and the damper blade must be protected according to the certified installation method \rightarrow see pages 27 to 28
- During the installation and plastering process, the actuating mechanism must be protected (covered) against damage and pollution. The damper casing should not be deformed during bricking in. Once the damper is built in, the damper blade should not grind against the damper casing during opening or closing.
- The distance between the fire damper and the construction (wall, ceiling) must be 75 mm at the minimum, according to EN 1366-2. If two or more dampers are to be installed in one fire separating construction, the distance between adjacent dampers must be 200 mm at the minimum, according to EN 1366-2.

Minimum distance between the fire dampers and the construction

- minimum distance 200 mm between dampers, according to EN 1366-2
- minimum distance 75 mm between damper and construction (wall/ceiling), according to EN 1366-2
- recommended minimum distance 150 mm necessary for access to the actuator
- recommended minimum distance 250 mm necessary for access to the manual control



230



Built in edge


Spiro design Built in edge 09 008 008 008 009


Built in edge

Flange design

"BUILT IN EDGE label" indicates the recommended edge of installation of a fire damper in the fire separating construction (wall/ceiling). The damper must be installed so that the entire damper blade (in the closed position) is located in the fire separating construction (wall/ceiling) and at the same time the actuating mechanism and inspection openings are freely accessible.

Dimensions of an installation opening





Statement of installations

Installation	wall/ceiling min. thickness [mm]	Method of installation	Fire resistance	Page
In solid wall construction	150	Mortar or gypsum	EI 180 (v _e i↔o) S - 500 Pa	27
In solid ceiling construction	150	Mortar or gypsum	EI 180 (h₀ i⇔o) S - 500 Pa	28





In solid wall construction


In solid wall construction - mortar or gypsum


EI 180 (v_e i⇔o) S - 500 Pa

For connection of following duct → see page 31









- 1 FDMR 180
- 2 Solid wall construction
- 3 Mortar or gypsum
- Clamp with threaded rod \rightarrow see pages 29 to 30 4
- 5 Duct





In solid ceiling construction


In solid ceiling construction - mortar or gypsum


El 180 (h₀ i⇔o) S - 500 Pa

■ For connection of following duct → see page 31









- 1 FDMR 180
- 2 Solid ceiling construction
- 3 Mortar or gypsum
- 4 Clamp with threaded rod \rightarrow see pages 29 to 30
- 5 Duct




V. SUSPENSION SYSTEMS


Mounting to the ceiling wall

- The dampers must be suspended using threaded rods and mounting profiles. Their dimensioning depend on the weight of the damper.
- The dampers and the duct must be suspended separately.
- Following air-conditioning duct must be suspended or supported so that all load transfer from the following duct
- to the damper flanges is absolutely excluded. Adjacent duct must be suspended or supported, as required by the duct suppliers.
- Threaded rods longer than 1,5 m must be protected by fire insulation.


Examples of anchoring to the ceiling construction Follow the instructions of fixing specialist or installation company



Hinge plates



If in doubt, always consult an anchor specialist engineer such as Halfen or Hilti.



1 Threaded rod M8 - M20

- 2 Nut M8 M20
- 3 Washer for M8 M20
- 4 Coupling Nut M8 M20
- 5 Anchor
- 6 Hinge plate min. thickness 10 mm
- 7 Concrete screw tested for fire resistance R30-R90, max. Tension up to 0.75 KN (length 35 mm)


Load capacities of threaded rods at the required fire resistance 120 min. < t ≤ 240 min.


Size	As [mm²]	Weight [kg]				
Size	AS [IIIII]	for 1 rod	for 2 rods			
M8	36,6	11	22			
M10	58	17,5	35			
M12	84,3	26	52			
M16	157	48	96			
M18	192	58,5	117			
M20	245	75	150			




Example of fixing FDMR 180 to the wall or ceiling


In solid wall construction











In solid ceiling construcion











Ø200-400

Quick closing system 2x screw M6×20. Fixing nut for threaded rod M8.

Ø450-800

2x screw connection M10x30 or threaded rods M10 Combined fixing nut for threaded rod M8+M10.


- 1 Solid wall construction
- 2 Solid ceiling construction
- 3 FDMR 180
- 4 Duct
- 5 Clamp with threaded rod
- 6 Damper bracket (according to order)
- 7 Nut M8 with anchor

The method of attachment must follow the minimum requirements for attachment and connection of ductwork in accordance with national regulations. Also, the elements can be suspended from the top, or supported from bottom, or fastened from the side.




Example of duct connection

SPIRO design



FLANGE design



- 1 FDMR 180
- 2 Duct
- 3 Extension piece (if required)
- 4 Damping pad
- Bolt assembly M8 (bolt M8x20 mm, 2 pcs large washer M8, nut M8)
- 6 Protective bonding conductor




VI. TECHNICAL DATA

Pressure loss

Pressure loss calculation

$$\Delta p = \xi \cdot \rho \cdot \frac{w^2}{2}$$

Determination of pressure loss by using diagram ρ = 1,2 kg/m³



Coefficient of local pressure loss

D	200	225	250	280	300	315	350	355
ξ	1,573	1,728	1,304	1,002	0,881	0,789	0,634	0,609
D	400	450	500	560	600	630	710	800
-	0,504	0,426	0,370	0,322	0,300	0,280	0,121	0,106



Noise data

Level of acoustic output corrected with filter A

 $L_{WA} = L_{W1} + 10 \log(S) + K_A$

 $\begin{array}{ccc} L_{WA} & & [dB(A)] & & level of acoustic output corrected with filter A \\ \\ L_{W1} & & [dB] & level of acoustic output L_{W1} related to the 1 m^2 section \\ \\ S & & [m^2] & duct cross section \\ \\ K_A & & [dB] & correction to the weight filter A \end{array}$

Level of acoustic output in octave ranges

 $L_{Woct} = L_{W1} + 10 \log(S) + L_{rel}$

L_{Woct}	[dB]	spectrum of acoustic output in octave range
L_{W1}	[dB]	level of acoustic output L_{W1} related to the 1 $\ensuremath{\text{m}}^2$ section
S	$[m^2]$	duct cross section
L_{rel}	[dB]	relative level expressing the shape of the spectrum

Tables of acoustics values

			Leve	el of acous	tic output	L _{w1} [dB] rel	ated to the	e 1 m² sect	ion			
		ξ [-]										
w [m/s]	0,1	0,2	0,3	0,4	0,6	0,8	1	1,5	2	2,5	3	3,5
2	9	11,5	14,7	16,9	20,1	22,3	24,1	27,2	29,4	31,2	32,6	33,8
3	16,7	22,1	25,3	27,5	30,7	32,9	34,6	37,8	40	41,7	43,2	44,4
4	24,2	29,6	32,8	35	38,1	40,4	42,1	45,3	47,5	49,2	50,7	51,9
5	30	35,4	38,6	40,8	44	46,2	47,9	51,1	53,3	55,1	56,5	57,7
6	34,8	40,2	43,3	45,6	48,7	51	52,7	55,8	58,1	59,8	61,2	62,4
7	38,8	44,2	47,3	49,6	52,7	55	56,7	59,9	62,1	63,8	65,2	66,4
8	42,3	47,7	50,8	53,1	56,2	58,4	60,2	63,3	65,6	67,3	68,7	69,9
9	45,4	50,7	53,9	56,1	59,3	61,5	63,3	66,4	68,6	70,4	71,8	73
10	48,1	53,5	56,6	58,9	62	64,3	66	69,1	71,4	73,1	74,5	75,7
11	50,6	56	59,1	61,4	64,5	66,7	68,5	71,6	73,9	75,6	77	78,2
12	52,8	58,2	61,4	63,6	66,8	69	70,7	73,9	76,1	77,9	79,3	80,5

	Correction to the weight filter A										
w [m/s]	2	3	4	5	6	7	8	9	10	11	12
K _A [dB]	-15	-11,8	-9,8	-8,4	-7,3	-6,4	-5,7	-5	-4,5	-4	-3,6

	Relative level expressing the shape of the spectrum L _{rel}								
	f [Hz]								
w [m/s]	63	125	250	500	1000	2000	4000	8000	
2	-4,5	-6,9	-10,9	-16,7	-24,1	-33,2	-43,9	-56,4	
3	-3,9	-5,3	-8,4	-13,1	-19,5	-27,6	-37,4	-48,9	
4	-3,9	-4,5	-6,9	-10,9	-16,7	-24,1	-33,2	-43,9	
5	-4	-4,1	-5,9	-9,4	-14,6	-21,5	-30,0	-40,3	
6	-4,2	-3,9	-5,3	-8,4	-13,1	-19,5	-27,6	-37,4	
7	-4,5	-3,9	-4,9	-7,5	-11,9	-17,9	-25,7	-35,1	
8	-4,9	-3,9	-4,5	-6,9	-10,9	-16,7	-24,1	-33,2	
9	-5,2	-3,9	-4,3	-6,4	-10,1	-15,6	-22,7	-31,5	
10	-5,5	-4	-4,1	-5,9	-9,4	-14,6	-21,5	-30	
11	-5,9	-4,1	-4	-5,6	-8,9	-13,8	-20,4	-28,8	
12	-6,2	-4,3	-3,9	-5,3	-8,4	-13,1	-19,5	-27,6	



VII. MATERIAL, FINISHING

- Damper casings are made from galvanized sheet metal without further surface treatment.
- Damper blades are made from fire resistant asbestos free boards made of mineral fibres.
- Manual control have cover made of mechanically resistant and durable plastic and the other parts are galvanized without further surface treatment.
- Thermal fuses are made of sheet brass, thickness 0,5 mm.
- Fasteners and springs are galvanized.
- According to the customer's requirements, dampers can be made of stainless steel material.

Specifications for stainless-steel design:

- Class A2 Food-grade stainless steel (AISI 304 EN 1.4301)
- Class A4 Chemistry-grade stainless steel (AISI 316, 316L EN 1.4401, EN 1.4404)

The respective stainless steel is the material for all components that are located or entering the damper inner space; components outside the damper casing are typically from galvanised sheet metal (fasteners for mounting the actuator or manual control, mechanical components except Item 4), frame components.

The following components, including the fasteners, are made from stainless steel at all times:

- 1) Damper casing and all components permanently attached
- 2) Blade holders including pins, metal parts of blades
- 3) Control components inside the damper (L-profile, pin with lever, rod, fasteners)
- 4) Parts of a manual control entering the inner space of a damper casing (lower sheet of a manual control, lock holder "1", lock lever "2", closing spring, 8 dia. stopper pin, manual control pin)
- 5) Inspection opening cover including the stirrup and fasteners (if they are parts of the cover)
- 6) Bearing for torque transfer from the lever with pin on the blade L-profile (made from AISI 440C)

The damper blade is made from a three boards of Promatect-H, thickness 20 mm, connected with galvanised nailed "U" connectors which are sealed with Promat K84 from the outside.

Thermal fuse is identical for all material variants of the dampers. Upon specification by customer, the thermal fuse can be made from A4 from stainless steel sheet metal.

Thermoelectric activation device BAT is modified for stainless-steel variant of the dampers; standard galvanised screws are replaced with stainless-steel M4 screws of corresponding class. Damper casing has stainless-steel riveting M4 nuts.

Plastic, rubber and silicon components, sealants, foaming tapes, glass-ceramic seals, housings, brass bearings of the blade, actuators, and end switches are identical for all material variants of the dampers.

Some fasteners and components are only available in one class of stainless steel; the type will be used in all stainless-steel variants.

The damper blade in the variant for chemical environments (Class A4) is always treated with a coating of chemically resistant Promat SR.

Any other requirements for the design will be considered atypical and will be addressed on an individual basis.



VIII. TRANSPORTATION, STORAGE AND WARRANTY

Logistic terms

- Dampers are delivered on pallets. As standard, the dampers are wrapped in plastic foil for protection during transport and must not be used for long-term storage. Temperature changes during transport can cause condensation of water inside the packaging and thereby cause corrosion of materials used in the dampers (e.g. white corrosion on zinc-coated items or mould on calcium silicate). Therefore, it is necessary to remove the transport packaging immediately after unloading to allow air to circulate around the product.
- The dampers must be stored in clean, dry, well ventilated and dust-free environment out of direct sunlight. Ensure protection against moisture and extreme temperatures (minumum temperature +5°C). The dampers must be protected against mechanical and accidental damage prior to installation.
- Another required packaging system should be approved and agreed by manufacturer. Packaging material is not returnable in case that another packaging system (material) is required and used and it is not included into final price of damper.
- Dampers are transported by box freight vehicles without direct weather impact, there must not occur any shocks and ambient temperature must not exceed +50°C. Dampers must be protected against impact when transported and manipulated. During transportation, the damper blade must be in the "CLOSED" position.
- Dampers must be stored indoor in environment without any aggressive vapours, gases or dust. Indoor temperature must be in the range from -30°C to +50°C and maximum relative humidity 95%.

Warranty

- The manufacturer provides a warranty of 24 months from the date of dispatch for the dampers.
- In case of using a Schischek actuator, the manufacturer provides a 12-month warranty for the actuator from the date of shipment.
- The warranty for fire dampers FDMR 180, provided by the manufacturer, is completely void if actuating, closing and control devices are unprofessionally handled by untrained workers or if electric components, i.e. limit switches,
- actuators, communication and supply devices and thermoelectric activation devices are dismounted.
- The warranty is void if dampers are used for other purposes, devices and working conditions than those allowed by these technical conditions or if the dampers are mechanically damaged during handling.
- If the dampers are damaged by transport, a record must be written down with the forwarder at reception for later complaint.



IX. ASSEMBLY, ATTENDANCE AND MAINTENANCE

- Assembly, maintenance and damper function check can be done only by qualified and trained person, i.e. "AUTHORIZED PERSON" according to the manufacturer documentation. All works done on the fire dampers must be done according international and local norms and laws.
- All effective safety standards and directives must be observed during damper assembly.
- To ensure reliable damper function it is necessary to avoid blocking the actuating mechanism and contact surfaces with collected dust, fibre and sticky materials and solvents.
- Flange and screw joints must be conductively connected to protect against dangerous contact. 2 galvanized lock washers that are placed under the head of one screw and a fastened nut are used for conductive connection.

Manual operation - actuator control without electric voltage

A special wrench (part of the actuator) can be used to manually turn the damper blade to any position. When the wrench is turned in the direction of the arrow, the damper blade rotates to its open position. As the blade rotation is stopped, in every position, the actuator will be locked. Unlocking is possible even manually as per instructions on the actuator, or by the activation of the supply voltage.

If the actuator is manually locked, the damper blade will not close in the event of a fire after the activation of the thermoelectric activation device BAT. To restore correct damper operation, the actuator must be unlocked (manually or by applying power supply).


Limit switches

- If the damper is equipped with limit switches and these switches are not used during operation (e.g. because of a project change), they can be left on the damper and not connected (they need not be dismounted).
- On the other hand, if the limit switch is to be added to the damper design, the change can be implemented by change kit.
- These facts must be recorded in the respective operation documentation of the damper (record books of the damper, fire logs, etc.) and subsequently, adequate function checks must be carried out.


Installation / fixing the damper

- The damper casing shall not be deformed in the course of bricking in.
- Once the damper is built in, the damper blade shall not grind on the damper casing during opening or closing.


Protection of the damper casing against buckling during installation, especially for DN over 400 mm!



WRONG!



Brace with wooden blocks



Brace with wedges




Change of manual control for the actuator or vice versa

DN 200 - DN 315



- 1 Damper
- 2 Mounting plate
- 3 Sealing of a mounting plate
- 4 Holder of thermoelectric activation device BAT
- 5 Thermal fuse
- 6 Manual control
- 7 Spring return actuator
- 8 Thermoelectric activation device BAT

DN 350 - DN 800



- 1 Damper
- 2 Mounting plate
- 3 Sealing cover
- 4 Sealing of a mounting plate
- 5 Cover of mounting plate
- 6 Thermal fuse
- 7 Manual control
- 8 Spring return actuator
- 9 Thermoelectric activation device BAT
- 10 Sensor sticker



Commissioning and revisions

- Before putting the damper into operation, serviceability checks and functional tests must be carried out including testing of functionality of all electrical elements. After putting into operation these serviceability checks must be carried at least twice a year. If no defect is found during two subsequent serviceability checks, these checks can be carried out once a year.
- In case that dampers are found unable to serve for their function for any cause, it must be clearly marked. The operator is obliged to ensure that the damper is put into condition in which it is ready for function and meanwhile he is obliged to provide the fire protection by another appropriate way.
- Results of regular checks, imperfections found and allimportant facts connected with the damper function must be recorded in the "FIRE BOOK" and immediately reported to the operator.
- Before entering the dampers with actuator into operation after their assembly and by sequential checks. Check of blade rotation into the breakdown position "CLOSED" can be done after disconnecting the actuator supply (e.g. by pressing the test button at the thermoelectric activation device BAT or disconnecting the supply from ELECTRICAL
- FIRE SIGNALISATION). Check of blade rotation back into the "OPEN" position can be done after restoration of power supply (e.g. by releasing the test button or restoration of supply from ELECTRICAL SIGNALISATION). Without power supply, the damper can be operated manually and fixed in any required position. Release of the locking mechanism can be achieved manually or automatically by applying the supply voltage. It is recommended to provide periodical checks, maintenance and service actions on fire equipment by authorized persons. The authorized persons can be trained by producer, or by authorized distributor. All effective safety standards and directives must be observed during fire damper assembly.
- Visual inspection of proper damper installation, inner area of a damper, damper blade, contact surfaces and silicon seal.
- For regular or exceptional inspection of interior of fire damper, micro-camera device can be used. On each fire damper is an inspection opening. In the case of inspection by camera, take out the black rubber cap, insert the camera inside the damper, check interior and at the end of inspection, put the rubber cap back tightly to cover the empty hole.

For dampers with manual control, following checks must be carried out

Check of a manual control and thermal fuse

- To check the function of the manual control proceed as follows:
- Turn the damper blade to "CLOSED" position as follows:
 - The damper blade is in "OPEN" position.
 - Press the control button of the manual control to turn the damper blade to "CLOSED" position.
 - Check the damper blade rotation to "CLOSED" position.
 - Damper blade closing shall be smooth and fast, the control lever shall be in "CLOSED" position.
- Turn the damper blade to "OPEN" position as follows:
 - Turn the control lever by 90°.
 - Check the damper blade rotation to "OPEN" position.
 - The lever will automatically lock in "OPEN" position.

Check of function and condition of the thermal fuse:

- To check the function and the status of the fuse it's possible to remove the manual control from the casing of the fire damper which is attached to the damper casing with four screws M6.
- Removing the thermal fuse from the fuse holder of a manual control, checks its correct functionality.
- The manual control is identified as M1 to M5, depending on the closing spring strength.



For dampers with actuators, following checks must be carried out

■ Check the rotation of the blade to "CLOSED" failure position after disconnection the power supply of the actuator (e.g. by pressing the test button on the thermoelectric activation device BAT or by disconnection the power supply from electrical fire signalization). Check the rotation of the blade back to "OPEN" position by restoring the power supply to the actuator (e.g. by releasing the test button or by restoring the power supply from electrical fire signalization).

Before putting the dampers into operation and during subsequent function checks, the following checks must be carried out for dampers with optical smoke detector

- The function checks of the optical smoke detector are to be carried out by employees of an authorized organization who have corresponding electrotechnical qualification and have been properly trained by the manufacturer. The function checks are to be carried out as a part of function checks of the fire dampers, at least 1x a year.
- For the function checks, the damper blade should be in "CLOSED" position with the fan off or with closed air regulation situated between the fan and the fire damper.
- Inspection opening disassembly
 - Unscrew the screws (2pcs) and remove the cover by tilting it.



Ensure each damper is fully checked for operational capability, control should be initiated from the control system or by manual control. Damper blades should open and close correctly and operation should be visually inspected and documented prior to handover.

Inspection opening detail

How to proceed after Tf1 or Tf2 fuses have been activated

- If the thermal fuse Tf1 is interrupted (due to temperature outside the duct), it is necessary to replace the spring return actuator. → see page 10
- If the thermal fuse **Tf2** is interrupted (due to temperature inside the duct), only the spare part ZBAT 72 (95/120/140) needs to be replaced (acc.to the activation temperature). → see page 10



X. ORDERING INFORMATIONS

Ordering key

Fire damper



EXAMPLE:

FDMR 180 SL 200 .40 - SL - spiro damper, 200 - damper diameter, .40 - design

Damper design	Additional digit
Manual control and thermal	.01
Manual control and thermal with a terminal switch ("CLOSED")	.11
Manual control and thermal with two terminal switches ("OPEN", "CLOSED")	.80
With actuator BF 230-TN (BFL, BFN 230-T) - voltage AC 230 V	.40
With actuator BF 24-TN (BFL, BFN 24-T), with smoke detector ORS 142 K and with supply device BKN 230-24-MOD (voltage AC 230 V)	.41**
With actuator BF 24-TN (BFL, BFN 24-T) - voltage AC/DC 24 V	.50
With actuator BF 24-TN (BFL, BFN 24-T), with smoke detector ORS 142 K (voltage AC/DC 24 V)	.51**
With communication and supply device BKN 230-24 and actuator BF 24-TN-ST (BFL, BFN 24-T-ST)	.60
With communication and supply device BKN 230-24-C-MP, with actuator BF 24-TN-ST (BFL, BFN 24-T-ST)	.61
With communication and supply device BKN 230-24-C-MP, with actuator BF 24-TN-ST (BFL, BFN 24-T-ST) and with smok detector ORS 142 K	e .61S**
With communication and supply device BKN 230-24MP and with actuator BF 24TL-TN-ST (Top-Line) for connection to MP-Bus	.62
With communication and supply device BKN 230-24-MOD, with actuator BF 24-TN-ST (BFL, BFN 24-T-ST)	.63
With communication and supply device BKN 230-24-MOD, with actuator BF 24-TN-ST (BFL, BFN 24-T-ST) and with smoke detector ORS 142 K	.63S**

^{*} For DN 350 only spiro design SL or SK can be ordered.

^{**} The smoke detector is not part of the damper in diameter DN 200 mm. The smoke detector is supplied separately.



Data label

Data label is placed on the damper casing (example)

MANDÍK, a.s. Dobříšská 550, 267 24 Hostomice, Czech Republic				
FIRE DAMPER - XXXX				恩級奧
DIMENSION:		DESIGN:		
SERIAL.NO.:		WEIGHT (kg):		MANUAL
CLASSIFICATION:				
TPM XXX/XX Cert. No.: 1391-CPR-XXXX/XXXX, DoP: PM/XXXX/XX/XX/X EN 15650:2010 CE				

The producer reserves the right for innovations of the product. For actual product information see www.mandik.com

