



CLEANLINESS CLASSIFICATION OF AIR-HANDLING COMPONENTS

ETS NORD AS

The classification working group set up by The Building Information Foundation RTS sr has approved the following product:

- NORDsilencer MSP AxB-600 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-900 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-1250 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-1500 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-1800 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-2000 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSP AxB-2400 (sinkitty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-600 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-900 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-1250 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-1500 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-1800 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-2000 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MSPI AxB-2400 (sinkitty, eristetty; A = 200...2400, B = 200...2000)**
- NORDsilencer MRPA AxB-600 (sinkitty, avattava; A = 300...2400, B = 300...2000)**
- NORDsilencer MRPA AxB-900 (sinkitty, avattava; A = 300...2400, B = 300...2000)**
- NORDsilencer MRPA AxB-1250 (sinkitty, avattava; A = 300...2400, B = 300...2000)**
- NORDsilencer MRPA AxB-1500 (sinkitty, avattava; A = 300...2400, B = 300...2000)**
- NORDsilencer MRPA AxB-1800 (sinkitty, avattava; A = 300...2400, B = 300...2000)**
- NORDsilencer MRPA AxB-2000 (sinkitty, avattava; A = 300...2400, B = 300...2000)**

300...2000)

**NORDsilencer MPP-1 AxB-150-150 (sinkitty, eristämätön; A = 200...2400,
B = 200...2400)**

as belonging to cleanliness class M1 for air-handling components.

The classification is valid until 24.01.2026.

ETS NORD AS has the right to equip its classified products with the classification mark and to use this classification mark when marketing these products.

The decision is in line with the requirements laid down in the Classification of Indoor Climate 2018 and the Cleanliness Classification of Air-handling Products: General Rules.

Building Information Ltd



Laura Apilo
Managing Director



Katri Leino
Secretary of the
Classification
Working Group