



CLEANLINESS CLASSIFICATION OF AIR-HANDLING COMPONENTS

ETS NORD AS

The classification working group set up by the Building Information Foundation RTS sr has approved the following product manufactured by your company:

NORDduct Round ventilation system:

Pressed air duct fittings:

Bend	NVP-Ø-15-90°	Ø100-200
End cup for duct	NAL-Ø	Ø100-400
End cup for fitting	NALM-Ø	Ø100-400
Reducer	NFC-Ø1/Ø2	Ø125/100 - 315/250
Reducer	NFCM-Ø1/Ø2	Ø125/100 - 315/250
Saddle	NPS-Ø1/Ø2	Ø100/100 - 400/315
Saddle	NSK-Ø	Ø100-200

Segment air duct fittings:

Bend	NV-Ø-15-90°	Ø250-1250
Bend 90°	NVK-Ø-90°	Ø250-1250
T-piece	NTK-Ø1/Ø3	Ø100/100 - 1250/1250
End cup for duct	NAL-Ø	Ø250-1250
End cup for fitting	NALM-Ø	Ø250-1250
Coupling	NI-Ø	Ø100-1250
Slide-In coupling	NIL-Ø	Ø100-1250
Female coupling	NM-Ø	Ø100-1250
Long male-female coupling	NILM-Ø	Ø100-200
Reducer, concentric	NFCV-Ø1/Ø2	Ø400/100 - 1250/1000
Reducer, eccentric	NFB-Ø1/Ø2	Ø125/100 - 1250/1000
Reducer, concentric	NFCVM-Ø1/Ø2	Ø400/100 - 800/630
Reducer, eccentric	NFBM-Ø1/Ø2	Ø160/125 - 1250/1000
Saddle	NPSK-Ø1/Ø2	Ø160/125 - 1250/1250
Saddle	NPSV-Ø1/Ø2	Ø400/400 - 1250/1250
Saddle	NSK-Ø	Ø250-1250
Air intake with mesh	NK-Ø	Ø100-1250
Air intake with mesh	NG-Ø	Ø100-1250

as belonging to cleanliness class M1 for air-handling components.


The classification is valid until 11.09.2024.

ETS NORD AS has the right to equip its classified products with the classification

The Building Information Foundation RTS sr
mark and to use this classification mark when marketing these products.

The decision is in line with the requirements laid down in the Classification of Indoor Climate 2018 and the Cleanliness Classification of Air-handling Products, General Rules.

THE BUILDING INFORMATION LTD



Laura Apilo
Managing Director



Katri Leino
Secretary of the Classification
Working Group