



CLEANLINESS CLASSIFICATION OF AIR-HANDLING COMPONENTS

ETS NORD AS

The classification working group set up by the Building Information Foundation RTS sr has approved the following products manufactured by your company:

NTP and NTPA:

- NTP-d-300, d= 100, 125, 160, 200
- NTP-d-600, d= 100, 125, 160,200, 315, 400, 500, 630,
- NTP-d-1000, d= 100, 125, 160,200, 315, 400, 500, 630,
- NTPA-d-300, d= 100, 125, 160,200,
- NTPA-d-600, d= 100, 125, 160, 200, 315, 400, 500, 630
- NTPA-d-1000, d= 100, 125, 160, 200, 315, 400, 500, 630

NKL and NKU:

- NKU-d-600, d= 100, 125, 160, 200
- NKU-d-1000, d= 100, 125, 160, 200
- NKL-d-600, d= 100, 125, 160, 200
- NKL-d-1000, d= 100, 125, 160, 200.

as belonging to cleanliness class M1 for air-handling components.
The classification is valid until June 20, 2022.

ETS NORD AS has the right to equip its classified products with the classification mark and to use this classification mark when marketing these products.

The decision is in line with the requirements laid down in the Classification of Indoor Climate 2018 and the Cleanliness Classification of Air-handling Products, General Rules.

THE BUILDING INFORMATION FOUNDATION RTS sr

Markku Hedman
Director General

Arja Valtanen
Secretary of the Classification
Working Group