

Commission Delegated Regulation (EU) No 574/2014  
amending Annex III to Regulation (EU) No 305/2011

1. Unique identification code of the product-type:  
**NORDsmoke smoke duct section**  
**E<sub>600</sub> 120 (v<sub>e</sub> - h<sub>o</sub>) S1500single**
2. Intended use/es:  
**Ventilation ducts product group for single compartment smoke extraction. It is used in a system to control the movement and/or containment of smoke and heat.**
3. Manufacturer:  
**ETS NORD AS, Peterburi tee 53, 11415 Tallinn, ESTONIA**  
**Tel: +372 680 7360, Email: info@etsnord.ee**
4. System/s of AVCP:  
**System 1**
5. Harmonised standard: **EN 12101-7:2011**  
Notified body/ies: **PAVUS, a.s., Nr.1391**
6. Declared performance/s:

Essential characteristics	Performance	Harmonized technical specification
<b>Fire resistance:</b>	<b>Single Compartment installations</b> <b>1500 Pa - pressure level 3</b>	EN 12101-7:2011
- integrity (E)	E <sub>600</sub> 120	
- insulation (I)	-	
- smoke leakage (S)	E <sub>600</sub> 120 S1500	
- mechanical stability (under E)	Conforms	
- maintenance of the cross section (under E)	Conforms	

7. Appropriate Technical Documentation and/or Specific Technical Documentation:  
**NORDsmoke products is in accordance with specifications contained in “NORDsmoke-Smoke extraction ducts” catalog.**

The performance of the product identified above is in conformity with the set of declared performance/s.  
This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Urmas Hiie  
Chairman of the Management Board  
ETS NORD AS

Tallinn 21.07.2021